

Sand 0.80 - 1.20mm
Typical Lab Analysis

SIEVE	0.80 - 1.20 Sand
#12	99.2
#14	97
#16	93.7
#18	55
#20	8.1
#25	0.9
Effective Size	0.86
Uniformity Coefficient	1.19
Specific Gravity	2.64
Acid Solubility	0.01